Optimization of UO₂ Fueled PWR Core Design

E. Greenspan et al.

University of California, Berkeley, CA 94720, gehud@nuc.berkeley.edu

> ARWIF-2005 Oak Ridge, TN February 16-18, 2005

NERI Project participants

E. Greenspan (PI), F. Ganda, Z. Shayer, D. Olander University of California, Berkeley, CA 94720,

gehud@nuc.berkeley.edu

N. Todreas (co-PI), J. Malen, C. Shuffler, J. Trant

Massachusetts Institute of Technology, Cambridge, MA 02139, todreas@mit.edu

B. Petrovic (co-PI) and H. Garkisch

Westinghouse Electric Company, Pittsburgh, PA 15235, petrovb@westinghouse.com

Presentation Outline

- Objective
- Approach
- Reference PWR and assumptions
- Neutronics
- Thermal hydraulics
- Clad mechanical integrity
- Vibration and wear
- Economics
- Conclusions

NERI 02-189 Project Objectives

- Assess the feasibility of improving the performance of PWR and BWR by using hydride fuel instead of oxide fuel:
 - *Economics*
 - Higher power per given volume core
 - Higher HM loading (with Th hydride) -> more energy per batch and longer cycles
 - Safety
 - Additional prompt negative reactivity insertion mechanism
 - Additional delayed negative reactivity insertion mechanism
 - Not so negative void coefficient for BWR
 - More uniform BWR assembly composition and pinwise power

Project Objectives (2)

- Assess the feasibility of improving the environmental friendliness of PWR and BWR by using hydride fuel instead of oxide fuel:
 - Higher discharge burnups
 - Pu disposition using fertile-free fuel
 - Pu (MA) multi-recycling in LWR
 - Use of Th as fertile fuel

Observation

Maximum permissible power density using hydride fuel far exceeds that contemporary oxide fueled PWR cores are designed to operate at

- Optimal lattice geometry:
 - fuel rod outer diameter D
 - Pitch-to-diameter ratio P/D

is highly different from the geometry range in present use by industry

Present Study Objective

Optimize the design of UO₂ fueled PWR core using same methodology we adopted for the search of optimal hydride fueled PWR cores

Study Approach

Search for that core design that gives the minimum Cost of Electricity (COE) in a retrofitted PWR

Need:

Attainable power
 Thermal hydraulic analysis
 Transient analysis
 Vibration analysis
 Attainable discharge burnup
 Neutronic analysis
 Clad mechanical integrity analysis

Study Approach (2)

Design variables:

- Outer fuel diameter D
- Pitch-to-diameter ratio P/D (square lattice)
- Uranium enrichment 5%, 7.5%, 10%
- Coolant pressure drop across core 29 psia or 60 psia
- Type of fuel rod support grid spacers or wire wraps
- Design constraints:
 - K_∞ > 1.05
 - Negative Doppler, moderator temperature and void ρ coef.
 - MDNBR
 - Peak fuel temperature
 - Coolant inlet and outlet temperatures fixed
 - Coolant pressure drop fixed

Study Approach (3)

Design constraints (cont.)

- Clad internal pressure
- Clad strain
- Clad water-side corrosion
- Constraints imposed by 5 vibration and wear mechanisms:
 - Vortex induced vibration
 - Fluid elastic instability
 - Turbulence induced vibration in cross and axial flow
 - Fretting wear
 - Sliding (or adhesive) wear

Reference PWR and Assumptions

South Texas Project Electric Generating Station

| Parameter | Value | Parameter | Value |
|---------------------------|---------------|--------------------------|------------|
| Effective core radius | ~1.83 m (72") | Inlet temperature | 294 C |
| Active fuel length | 4.26 m (168") | Core enthalpy rise | 204 kJ/kg |
| Fission gas plenum length | 17.8 cm (7") | System pressure | 2250 psia |
| Clad outer diameter, D | 9.5 mm | Radial peaking factor | 1.65 |
| Square lattice pitch, P | 12.6 mm | Axial peaking factor | 1.55 |
| Pitch-to-diameter ratio | 1.326 | Average linear heat rate | 174 W/cm |
| Number fuel rods per core | 50956 | Average specific power | 38.38 W/gU |
| $Power \ level^*$ | 3800 MWt | Average discharge burnup | 60 GWD/tHM |

Parameters in Italics are variables of this study. The other parameters are fixed

| Outer diameter (mm) | Clad thickness (mm) | Gap thickness (mm) |
|---------------------|------------------------------|-------------------------------|
| D < 7.747 | 0.508 | 0.0635 |
| D > 7.747 | 0.508 + (D - 7.747) * 0.0362 | 0.0635 + (D - 7.747) * 0.0108 |

Neutronics - methodology

Unit cell analysis using SAS2H sequence of SCALE4.4
 Good agreement with OECD/NEA MOX benchmarks

- Assuming 3 batches
 - Same power density
 - Core $k_{\infty}(\alpha)$ is arithmetic average of batch $k_{\infty}(\alpha)$

• Accounting for non-linearity of k_{∞} with BU

• k_{∞} (EOC) = 1.05

- Finding boron concentration in water required to bring k_∞ to 1.05 at any point in time
- Calculating Doppler, MTC and reactivity effect due to 5% voiding – as a function of BU
- Amount of IFBA 0.2D(cm)/0.95 mg/cm ¹⁰B

Neutronics – illustration



MTC

Doppler

Neutronics – results; 5% enriched U



Discharge BU (GWD/tHM)

MTC (pcm/k)

Thermal hydraulics - methodology

- Using VIPRE-EPRI subchannel analysis
- Verified against VIPRE full-core analysis
- MATLAB scripts to automate VIPRE execution
- W3-L correlation for MDNBR

| Constraint | Value |
|--|-----------|
| MDNBR | 2.17 |
| Peak/average fuel temperature (°C) | 1400/2800 |
| Present/future Core pressure drop (Psia) | 29/60 |

Constraints:

Thermal hydraulics - results



29 psia

60 psia

Clad integrity - methodology

Using FRAPCON

Constraints:

- Clad corrosion, water side: < 0.1 mm, independent of D
- Clad strain: < 1% in tension</p>
 - External coolant pressure
 - Thermal expansion (fuel and clad)
 - Fuel swelling
- Clad internal pressure: < 2500 psia</p>
 - Gaseous fission products
 - □ Helium from ¹⁰B of IFBA

Clad integrity - results



29 psia



Fuel rod vibration - methodology

- Vibration mechanisms:
 - Fluid elastic instability
 - Vortex shedding lock-in
 - Turbulence induced vibration in cross and axial flow
- Cladding wear mechanisms:
 - Sliding wear
 - Fretting wear

Fuel rod vibration – results: attainable power



29 psia



Fuel rod vibration – results: cycle length



29 psia



Accidents and transient analysis (limited) – methodology & results

- Using VIPRE-EPRI subchannel analysis
- MATLAB scripts to automate VIPRE execution
- Considering:
 - An overpower transient due to control rod bank withdrawal at full power – DNB should not occur
 - A large break LOCA peak clad temperature < 2200°F</p>
 - A complete LOFA DNB should not occur

• Findings:

| Pressure drop | Peak power MW _{th} | D (mm) | P/D |
|---------------|-----------------------------|--------|------|
| 29 psia | 4104 (vs. 4245) | 7.1 | 1.47 |
| 60 psia | 4990 (vs. 5045) | 6.5 | 1.39 |

Economics - methodology

- *"Major backfit" scenario; replacement of:*
 - Steam generators
 - High pressure turbine
 - Pressure vessel head and core internals
- OECD/NEA cost data and costing methodology
- Fuel assembly fabrication cost:
 - 50% of reference proportional to U loading
 - 50% of reference proportional to # of fuel rods per assembly
- Outage time of reference plant is 20 days:
 - 13 days for refueling fixed
 - 7 days for maintenance scales with cycle length (same per year)

Economics – costing assumptions

| Cost Component | Unit Price |
|--------------------|------------------------|
| Mining/Ore | \$41/kg _{HM} |
| Conversion | $8/kg_{HM}$ |
| Enrichment | $108/kg_{SWU}$ |
| Fabrication | \$275/kg _{HM} |
| Spent Fuel Storage | \$250/kg _{HM} |
| Waste Disposal | 1 mill/kWh |

| Transaction Time | Value |
|----------------------|--------------------|
| Fuel Fabrication | 1 yr |
| Uranium Enrichment | 1.5 yr |
| Uranium Conversion | 1.5 yr |
| Uranium Ore Purchase | 2 yr |
| Spent Fuel Storage | - T _C * |
| | |

* T_c is the cycle length. A negative sign implies that the storage costs need to be referred back in time to the reference date

| Mass Loss Fraction | Value |
|--------------------|--------|
| Mining/Ore | 0 |
| Conversion | 0.005 |
| Enrichment | Varies |
| Fabrication | 0.01 |

| O&M function | | | |
|------------------|---------------------|--|--|
| Variable | Cost | | |
| Refueling Outage | \$800,000/day | | |
| Forced Outage | \$100,000/day | | |
| Replacement | 30 mills/kWh | | |
| Fixed | | | |
| Personnel | \$150,000/person-yr | | |
| Number Personnel | 600 | | |
| Refueling Outage | 20 days/cycle | | |
| Forced Outage | 1% | | |
| Availability | 99% | | |

Economics – costing assumptions

| Characteristic | Value | | Price | Scaling |
|----------------------|--------|---------------------|----------------------|---------|
| Thermal Efficiency | 0.33 | Component | (\$10 ⁶) | Factor |
| Number of Batches | 3 | Steam Generators | 100 | 0.6 |
| Plant Life Extension | 20 vrs | Vessel Head | 25 | - |
| | | Core Internals | 25 | - |
| | | Turbine Generator | 338 | 0.8 |
| | | Existing Fuel Value | 67 | - |



60 psia





29 psia



Lowest COE designs

| | | <u>Reference</u> | <u>29 psia</u> | <u>60 psia</u> |
|--------------------|-----------------|------------------|----------------|----------------|
| COE (mills/k | N-hre) | 19.7 | 18.0 | 17.9 |
| Power (MWth | n) | 3800 | 3800 | 4929 |
| Geometry: | D (mm) | 9.5 | 7.13 | 6.5 |
| | P/D | 1.326 | 1.47 | 1.39 |
| Rod Number | | 50,956 | 73,966 | 98,699 |
| U Inventory | (kg_HM) | 99,010 | 81,581 | 87,104 |
| Specific Powe | er (kWth/kg_HM) | 38.4 | 46.6 | 56.6 |
| Linear Heat F | Rate (kW/ft) | 5.30 | 3.67 | 3.56 |
| Cycle Length (yrs) | | 1.5 | 1.17 | 0.9 |
| Burnup (MWd/kg_HM) | | 60 | 56.55 | 52.3 |
| MDNBR | | 2.17 | 2.17 | 2.65 |
| Peak Fuel Tel | mp (F) | | 1906 | 1879 |

Conclusions

| Pressure drop | Reduction in COE | Increase in power density | Optimal /reference D (cm) | Optimal/ reference P/D |
|------------------|---------------------|---------------------------------|---------------------------------|------------------------------|
| 29 psia | 12% | 0% | 0.71/0.95 | 1.47/1.326 |
| 60 psia | 12.5% | 30% | 0.65/0.95 | 1.39/1.326 |

Our preliminary analysis indicates:

- It may be possible to reduce COE by ~12% by going to thinner fuel rods of a larger P/D ratio
- It may be possible to increase core power density by ~ 30% by going to smaller D, larger P/D and ~60 psia coolant pressure drop

Conclusions (2)

It may be possible to design new PWR for nearly 2 GWe per unit using the same pressure vessel dimensions to be used for the 1500 MWe PWR

Question:

Why industry is not using lower D, higher P/D, higher ∆P core designs???

An alternative promising design approach – wire wrap in hex lattice



An alternative promising design approach – wire wrap in hex lattice

Preliminary results:

Using hexagonal lattice with wire wraps instead of grid spacers, it may be possible to significantly increase core power density without increasing pressure drop above 29 psia. For example:

With D=0.65 cm and P/D = 1.42
Power density can be increased by ~30%