

Studsvik

Validation of activity determination codes and nuclide vectors


Workshop on Radiological
Characterisation for Decommissioning
Studsvik, 17th –19th April 2012
Klas Lundgren
Arne Larsson



Background

- Studsvik was founded in 1947 as a state own research company with the mission to develop nuclear power in Sweden.
- Today Studsvik is a private commercial company focused on providing high quality services to the domestic and international nuclear industry.
- Already in the old days Studsvik paid a lot of attention in materials characterisation. The interest in characterisation of waste and in characterisation for decommissioning has increased over time.
- Studsvik has built several theoretical and practical references from characterisation of materials, systems and buildings for decommissioning.

Introduction



Initial facts



- All radioactive or potentially radioactive objects need to be characterised - either for clearance or disposal
- Critical parameters for characterisation differs between routes. Has to be considered already in the validation planning
- Characterisation for clearance is easier than characterisation for disposal
- Quality assurance of activity assessment calculations and nuclide vectors requires validation require physical measurements
- Good understanding, validated and documented nuclide vectors and assessment calculations supports graded approach – saves money and time

Well developed areas

- Activity assessment for easy to measure nuclides (gamma) inside and close to the reactor pressure vessel of NPPs.
- Characterisation of contaminated metals subject to free release (clearance) either directly or after treatment.
- Screening of nuclides in the clearance process i.e. nuclides without importance for clearance



Areas with development potentials


- Validation of calculation models for hard to measure nuclides.
- Validation of activity assessment calculations for systems with low contamination levels far from the reactor grid.
- Nuclide composition after treatment for in a repository perspective critical hard to measure nuclides (such as C-14 and Cl-36).
- Characterisation models for nuclear facilities other than NPPs and where nuclide vectors have varied by time.
- Nuclide screening models for waste to be disposed



Importance of good understanding

Process parameters:

- How the materials, systems and buildings have been contaminated
- Variations in operations and how it has effected the activity build up
- The way waste treatment affects the nuclide inventory and how treatment effects can simplify the validation process



Key issues for a successful validation

- Review documentation of the nuclide vector development including boundary conditions.
- Define objectives and purpose of validation.
- Analyse the distribution and behavior of the different nuclides i.e. identify uncertainties in using nuclide vectors. Make sure all process parameters are understood.
- Identify and focus on key nuclides – perform a careful screening.
- Secure comparability and traceability - careful planning and selection of validation objects.
- Form and evaluate different fail test methods as tools for validation.

Determination of activity inventories

				V
		1.0E+09	2.4E+09	4.5E+09
		1.0E+02	3.6E+05	6.6E+05
	09			
	3E+13	2.9E+07	4.7E+08	2.1E+09
	9.0E+15	7.6E+09	6.4E+10	4.2E+09
	2.3E+15	1.0E+10	1.8E+11	4.5E+09
	2.2E+13	4.0E+07	8.0E+08	1.9E+09
	2.8E+15	5.2E+09	9.5E+10	2.5E+09
90	5.6E+08	1.3E+08	6.1E+08	1.1E+09
94	3.5E+10	8.3E-03	3.3E+00	6.2E-01
c-99	5.1E+10	2.2E+04	1.2E+07	2.3E+07
Sb-125	6.7E+11	2.3E+08	2.1E+09	1.8E+09
I-129	1.5E+05	6.1E+03	5.5E+04	1.0E+05
Cs-134	3.9E+09	6.7E+04	1.8E+09	3.3E+09
Cs-135	6.9E+05	3.8E+04	3.7E+05	6.8E+05
Cs-137	9.4E+10	5.7E+08	2.6E+10	4.9E+10
Eu-152	2.0E+11			
Eu-154	1.4E+10	4.1E+04	2.2E+07	4.2E+07
Eu-155	5.2E+09	1.0E+04	6.6E+06	1.2E+07
Pu-238	1.5E+07	4.3E+04	1.7E+07	3.3E+07
Pu-239	7.0E+06	8.0E+03	3.1E+06	6.0E+06
Pu-240	3.9E+06	1.3E+04	5.1E+06	9.7E+06
Pu-241	3.0E+08	6.5E+05	2.6E+08	5.4E+08
Am-241	8.7E+06	2.8E+04	1.0E+07	1.9E+07
m-244	1.0E+07	2.4E+04	9.5E+06	2.0E+07
[kg]	2.3E+06	1.2E+06	3.1E+05	2.1E+06

Determination of decommissioning activity inventories in reactors – Reference list

- **Olkiluoto 1 and 2**
 - Process systems, database modification and update (2008)
- **Barsebäck 1 and 2**
 - Project “RivAkt”, Total activity assessment (2007), evaluation of performed system decontaminations (2008), improved assessment of activity in reactor internals (2012)
- **Ringhals 1, 2, 3 and 4**
 - Total activity assessment (2007), updates (2010, 2012)
- **Forsmark 1, 2 and 3**
 - Total activity assessment (2010), update (2012)
- **Oskarshamn 1, 2 and 3**
 - Total activity assessment (2010), update (2012)
- **Ågesta (PHWR, closed in 1974)**
 - Total activity assessment (2010)

Source terms considered

- **Neutron induced activity in internals, RPV and biological shield (insulation, concrete and reinforcement)**
 - Neutron flux (MCNP), material compositions, neutron activation calculations (IndAct, FISPACT)
- **Activated corrosion products on system surfaces (“Crud”)**
 - Model CrudAct for BWR and PWR for primary system
 - Relative distribution between different systems based on dose rate and gamma scan measurements
- **Fission products and actinides from leaking fuel:**
 - SAR leakage models combined with plant data
 - Fuel dissolution results in:
 - Actinide incorporation in system oxides (long memory effect)
 - Tramp U on core → Noble gas daughters in offgas systems
- **Contamination of concrete from system leakage**

Nuclides considered

- **Initially 28 nuclides:**

- H3, C14, Cl36, Ca41, Fe55, Ni59, Co60, Ni63, Sr90, Nb94, Tc99, Ag108m, Cd113m, Sb125, I129, Cs134, Cs135, Cs137, Sm151, Eu152, Eu154, Eu155, Pu238, Pu239, Pu240, Pu241, Am241, Cm244

- **Further 20 nuclides included in 2012 update:**

- Be10, Se79, Mo93, Zr93, Nb93m, Ru106, Pd107, Sn126, Ba133, Pm147, Ho166m, U232, U236, Np237, Pu242, Am242m, Am243, Cm243, Cm245, Cm246

- **Some additional nuclides being discussed, e.g.:**

- Fe60 ($T_{1/2} = 1.5 \text{ My}$)
 - Fe58 (n, γ) Fe59 (n, γ) **Fe60** (β^-) Co60m (IT) **Co60**
Fe60 has high dose factors both for ingestion and inhalation


- **Additional nuclides call for improved evaluation and validation processes**

Recent calculation results for typical BWR fuel crud – FISPACT-2007 – Ingestion and inhalation dose after decay 1000 y

- Specific activity (Bq per gram fuel crud) has been calculated
- A decay period of 1000 y has been considered, and the activity has been recalculated to ingestion and inhalation doses per gram fuel crud
 - Fe60 is on the Top10-list
- **NOTE: The transport properties in the environment is not considered**

Decay: 1000 y			
	Ingestion		Inhalation
Nuclide	mSv/g	Nuclide	mSv/g
Ni 59	1.3E-01	Nb 94	3.4E+00
Nb 94	1.2E-01	Ni 59	9.0E-01
Ni 63	4.2E-02	Ni 63	3.6E-01
Mo 93	1.9E-02	Ag108m	3.3E-02
Ag108m	2.0E-03	Zr 93	1.8E-02
Zr 93	7.8E-04	Mo 93	1.4E-02
Nb 93m	7.2E-04	Nb 93m	1.1E-02
Tc 99	2.5E-04	Tc 99	5.2E-03
Fe 60	1.4E-04	Fe 60	3.7E-04
Re186m	6.8E-06	Nb 91	7.1E-05
Total	3.1E-01	Total	4.7E+00

Examples of performed validations



Example of validation: Ringhals-3 Steam Generator

- **Higher waste activity than determined by in-plant gamma scanning**
 - Complicated geometry to evaluate gamma scans (only peripheral tubes)
- **Ni63/Co60 ratio in line with earlier assessments**
- **C14 was detected in the blasting waste**
 - The detected amount corresponds to about 0.24% produced in the coolant during one year
 - Additional evaluation initiated

Waste activity from processing in Studsvik				
Bq, 1995-06-01				
Nuclide	Blasting	Melt	Other	Total
Co60	2.27E+12	2.20E+11	1.07E+12	3.56E+12
Ni63	2.23E+11	2.16E+10	1.05E+11	3.50E+11
Ni63/Co60				9.83E-02
C14	5.68E+08	5.51E+07	2.77E+08	9.00E+08
C14/Co60				2.53E-04
In-plant gamma scanning on SS and Inc				
Bq, 1995-06-01				
Nuclide		Inc600	SS	Total
Co60		8.83E+11	9.20E+10	9.75E+11

Ni63 measurements performed by Studsvik
C14 measurements performed by Ringhals AB

Example of validation:

B1 & 2 – Activity removed from system decontaminations

ref.date	2007-11-01	2007-11-01	2007-11-01	2007-11-01
	B1/2008 [Bq]	B2/2007 [Bq]	B2/2002 [Bq]	TOTAL [Bq]
Co-60	1.33E+12	2.13E+12	7.55E+11	4.21E+12
Fe-55	6.72E+11	1.28E+12	6.69E+11	2.42E+12
Mn-54	8.01E+08	3.98E+10	7.91E+08	4.14E+10
Ni-59	1.68E+09	1.18E+09	1.63E+09	4.50E+09
Ni-63	2.13E+11	1.59E+11	2.13E+11	5.86E+11
Sb-125	2.30E+10	6.60E+10	2.44E+10	1.13E+11
Tc-99	8.44E+05	3.25E+05	4.48E+05	1.62E+06
Pu-238	3.41E+06	4.69E+06	1.52E+07	2.33E+07
Pu-239	4.13E+05	5.44E+05	1.76E+06	2.72E+06
Pu-240	6.75E+05	8.89E+05	2.87E+06	4.44E+06
Pu-241	1.07E+08	1.83E+08	5.93E+08	8.83E+08
Am-241	1.57E+06	4.03E+05	1.30E+06	3.28E+06
Cm-244	3.56E+06	5.79E+06	1.87E+07	2.81E+07

Memory effect of fuel dissolution in B2 in 1992 (**totally about 10 g U**)

Example of validation:

B1 – Comparison between measured and calculated activity in RPV insulation and biological shield

	<i>Capasil [Bq/kg]</i>		Al sheet [Bq/kg]	
<i>Nuclide</i>	<i>Calculated</i>	<i>Measured</i>	<i>Calculated</i>	<i>Measured</i>
Co-60	3.3E5	2.4E5	8.4E4	6.3E4
Cs-134	1.4E5	4.2E4		
Mn-54	5.6E5	5.2E5	3.2E4	2.0E4
Zn-65			1.6E5	6.3E4

	<i>Concrete [Bq/kg]</i>		Reinforcement [Bq/kg]	
<i>Nuclide</i>	<i>Calculated</i>	<i>Measured</i>	<i>Calculated</i>	<i>Measured</i>
Co-60	7.6E5	3.0E5	2.7E7	6.2E6
Mn-54			1.3E7	5.3E6
Cs-134	9.0E4	5.5E4		
Eu-152	1.8E6	1.3E6		
Eu-154	1.6E5	1.2E5		

Example of validation:

F1/2/3 – Turbine components

- **Totally about 1300 tons of turbine components**
 - About 95% subject to clearance, 71% direct clearance
 - Remaining 5% is waste for disposal
- **Totally about 1.6 GBq Co60**
 - In line with assessment calculations
- **Totally about 0.09 GBq Cs137**
 - Higher than assessment calculations
 - TU → Xe137 (3.8 min) → Cs137
 - Dominating fraction expected in off-gas systems
- **Other nuclides detected**
 - Mn54, Co60, Zn65, Ag110m

	Weight, kg	Activity, Bq		Bq/kg
		Co60	Cs137	Co60
Exempted ¹	940234	4.3E+08		4.6E+02
Ingots ²	315745	8.6E+08		2.7E+03
Waste ³	64290	3.0E+08	9.3E+07	4.7E+03
Total	1320269	1.6E+09	9.3E+07	1.2E+03
1 - Exempted ingots (limit Co60 <1000 Bq/kg)				
2 - Ingots to be exempted after some decay				
3 - Process waste				

Conclusions and the way forward



Conclusions

- Validations of calculated activity assessments have been performed in certain areas, mainly for easy to measure nuclides – good results and deep understanding
- The clearance route is in general well validated
- The most important validations, in a repository long term perspective, are often weak if started up
- Joint efforts can make change

A way forward

Form an international project for building up industry knowledge regarding activity assessment in metals from decommissioning to support validation and optimisation of radioactivity assessment codes.

- Open books inside project – joint financing - common learning
- Use retired components sent for treatment as objects for validations
- Special areas of interest
 - long lived beta-emitting nuclides
 - nuclide distribution, behavior and effects of treatment
 - optimisation of sampling and evaluation

Studsvik